



# FOREST INDUSTRIES (TRAVANCORE) LIMITED

( A KERALA GOVERNMENT COMPANY)  
THAIKKATTUKARA P.O., ALUVA - 683 106,  
KERALA STATE  
CIN: U02001KL1946SGC000373  
GST NO: 32AAACF4562B1Z9

FIT/PLG/04/2025-26/2856

Dated 18.02.2026

## INVITATION OF QUOTATION

Quotations are Invited for onsite **Electrification Work at Konni Block Panchayath, Elakolloor P.O, Pathanamthitta**. Quotation should be sent to "THE MANAGING DIRECTOR, FOREST INDUSTRIES TRAVANCORE LTD, THAIKKATTUKARA, ALUVA, PIN -683106" so as to reach the undersigned on or before 24.02.2026. All details are given below.

No.	Description	Qty
1.	Electrification Work	LS

For further details, please contact us our working time 9.30 am to 5.00 pm.

Managing Director

S/d

Forest Industries (Travancore) Limited

Encl: List attached.

Sl.no	Specification	Qty	Unit
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface / recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm. FRLS PVC insulated copper conductor single core cable etc as required.Group B	9	Point
2	Wiring for group controlled (looped) light point/fan point/exhaust fan point/ call bell point ( without independent switch etc.) with 1.5 sq. mm FRLS PVC insulated copper conductor single core cable in surface/ recessed PVC conduit, and earthing the point with 1.5 sq. mm FRLS PVC insulated copper conductor single core cable etc. as required.Group B	7	Point
3	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2x1.5 sq.mm + 1x1.5 sq.mm earth wire	80	Metre
4	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2X 2.5 sq. mm + 1 X 2.5 sq. mm earth wire	25	Metre
5	Wiring for circuit/ submain wiring alongwith earth wire with the following sizes of FRLS PVC insulated copper conductor, single core cable in surface / recessed medium class PVC conduit as required 2 X 4 sq. mm + 1 X 4 sq. mm earth wire	50	Metre
6	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.6 pin 15/16 amp socket outlet	1	Each
7	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.3 pin 5/6 amp socket outlet	2	Each
8	Supplying and fixing following modular switch/ socket on the existing modular plate & switch box including connections but excluding modular plate etc. as required.5/6 amps switch	2	Each
9	Supplying and fixing following size/ modules, GI box alongwith modular base & cover plate for modular switches in recess etc as required.1 or 2 Module (75mmX75mm)	2	Each
10	Supply and Fixing the following modular switches & accessories in the existing front plates and giving necessary connections as required (RoHS compliant )32A DP switch with indicator	1	Each
11	Supply and Fixing the following modular switches & accessories in the existing front plates and giving necessary connections as required (RoHS compliant )16A 3 pin plug top	1	Each



12	Supplying and fixing 5A to 32 A rating, 240/415 volts, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole	4	Each
13	Supply of 9 watt panel type round LED ceiling light with 16/0.20mm 3 core round copper conductor flex wire conforming to relevant ISS or extending the original wiring and giving connections etc. as required	14	Each
14	Supply, conveyance, installation, testing and commissioning of pre-wired light fitting of all types complete with all accessories etc. mounting on surface of 12 V, 150 W, 12.5 A LED drive and including giving connections with required length of 16/0.20 mm PVC insulated and PVC sheathed 3 core round copper conductor flex wire conforming to relevant ISS or extending the original wiring and making good the surface as required giving connections etc. Make LEDWELL/ equivalent.	5	Each
15	Supply of 18 watt panel type round LED ceiling light with 16/0.20mm 3 core round copper conductor flex wire conforming to relevant ISS or extending the original wiring and giving connections etc. as required	6	Each
16	Conveyance and fixing charges of recess mounting down light fittings of all types complete with all accessories in the existing opening of false ceiling, giving connections with the existing wire etc., as required.	20	Each
17	Supply, conveyance, installation, testing and commissioning of wall mounting type 2 ton 5 star 7 in 1 inverter split AC unit (having one indoor unit and one outdoor unit) fitted with hermetically sealed compressor (copper) operating on single phase AC supply with evaporator and condensing unit made of copper tubes with aluminium fins, cordless remote control, filtering, copper piping for both suction and discharge of three (3) meters length with protection covering for piping of suitable size of medium PVC pipe with control cable up to 3 meters, outdoor support stand etc. as per required with one year comprehensive warranty for product and 5 year on PCB and motor, 10 years on compressor.	1	Each
18	Supply and drawing the following sizes of multi-core PVC insulated & FRLS PVC sheathed 650/1100 V grade copper conductor round flexible cables conforming to IS 694 part I 1960 in the existing surface / recess conduit as required including giving necessary connections of the following sizes. 3 core 4.00 sq mm	10	Metre
19	Dismantling existing 1 ton split air conditioner unit including compressor from the existing position without any further damage and conveying to the nearest store.	1	Each

